

Conesville Plant

Notice of Assessment Monitoring Program Establishment

Ash Pond Complex

On February 27, 2018, it was determined that Conesville Plant's Ash Pond had statistically significant increases over background for Boron, Chloride, Fluoride, and pH. An alternative source demonstration was not successful within the 90 day period as allowed for in 257.94(e)(2) prompting the initiation of an assessment monitoring program, which was established on April 13, 2018. Therefore this notice is being placed in the operating record in accordance with the requirement of 257.94(e)(3).