

Conesville Plant

Notice for Initiating an Assessment of Corrective Measures

CCR Unit - Ash Pond Complex

This notice is being provided, as required by 40 CFR 257.95(g)(5), that an Assessment of Corrective Measures was initiated on March 26, 2019 for Conesville Plant's Ash Pond Complex due to the statistically significant concentrations detected above the established groundwater protection standards for arsenic, molybdenum, and lithium.