

Professional Engineer's Certification:

I certify that I have reviewed the design/construction records related to the CCR unit noted below or discussed the construction of such unit with personnel to attest that it was not constructed with a liner meeting the requirements of section 40 CFR 257.71 (a).

AEP Generation Resources  
Conesville Plant  
Ash Pond

*Gary F. Zych*

---

Gary F. Zych, P.E.  
American Electric Power Service Corporation  
Engineering Services

