

Conesville Plant

Notice of Statistically Significant Levels (SSLs) above the  
Groundwater Protection Standard (GWPS)

CCR Unit – Ash Pond

As required by 40 CFR 257.95(g), this is a notification that on January 8, 2019 arsenic, lithium and molybdenum were detected at SSLs above the GWPSs. This notification is being placed in the operating record, as required by 40 CFR 257.105(h)(8).